



Planning Strategy  
Brent Council

By Email: [planningstrategy@brent.gov.uk](mailto:planningstrategy@brent.gov.uk)

## Brent Draft Local Plan Consultation

Dear Sir/Madam,

Thank you for consulting Thames Water on the above document. Thames Water are the statutory sewerage undertaker for the whole Borough and the statutory undertaker for water supply for part of the Borough. Please find enclosed a completed response form containing our comments on the draft plan. Further background and supporting information is also provided below.

We are pleased to see that some of the comments provided at the preferred options stage have been taken into account or the position of the Council has been clarified within the consultation statement.

### Site Specific Comments

Comments regarding the potential requirement for upgrades have been provided previously. Updated site specific comments on the proposed allocations within the draft Local Plan document have been appended to this letter for information.

In relation to the allocations within the draft Local Plan, the addition of the reference to the need for early engagement with Thames Water is welcomed. However, this could be clarified to indicate that such engagement should take place prior to the submission of planning applications. It is important for developers to engage with Thames Water prior to submitting their planning applications to discuss the infrastructure requirements necessary to support their development. Where network improvements are required to support development the timescales to deliver these should not be underestimated. Local upgrades can take 18 months to 3 years to be delivered with more strategic upgrades taking 3 to 5 years.

### Specific Policy Comments

With regard to Policy BD3 on basement development, there are concerns regarding the absence of a requirement for a pumped device to protect properties from the risk of sewer flooding. While properties may be at low risk at present this can change over time with additional flows added to the sewerage network and climate change resulting in more intensive storms. Such storms can affect foul sewer networks as a result of miss-connections. Building Regulations do not provide an absolute requirement for pumped devices and as such it is considered that a policy requirement for a pumped device will help ensure that new basement development is protected from the risk of sewer flooding for the lifetime of development.

## **Further Comments**

In relation to our comments where we make reference to encouraging developers to contact us early to discuss proposals. Further information for developers and land promoters on pre-planning enquiries can be found at:

<https://www.thameswater.co.uk/preplanning>

I trust the above and enclosed comments are satisfactory, but please do not hesitate to contact me if you have any queries.

Yours sincerely,

**Thames Water Utilities Ltd**

<b>Site ID</b>	<b>Site Name</b>	<b>Water Response</b>	<b>Waste Response</b>	<b>Internal Comments</b>
59929	1-2 Dowling parade off Bridgehill Close London HA0 1AJ	Affinity Water	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	N/A
33962	BCSA1: ASDA/THE TORCH/KWIKFIT	Affinity Water	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	N/A

54785	BCSA10: York House, Empire Way, Wembley, HA9	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	--	----------------	--	-----

54831	BCSA11: COLLEGE OF NORTH WEST LONDON WEMBLEY Wembley Park Drive, Wembley, HA9 8HQ	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	---	----------------	--	-----

59878	BCSA12: LAND TO SOUTH OF SOUTH WAY, Wembley, HA0	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	--	----------------	--	-----

33954	BCSA2: STADIUM RETAIL PARK and FOUNTAIN STUDIOS	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	---	----------------	--	-----

59875	BCSA3: Brook Avenue, Wembley, HA9	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>A critical trunk sewer runs under the road adjacent to this site which would need to be considered.</p>
-------	-----------------------------------	----------------	--	--

33964	BCSA4: FIFTH WAY/EURO CAR PARTS	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>A critical trunk sewer runs through this site which would need to be considered</p>
-------	---------------------------------	----------------	--	--

36848	BCSA5: OLYMPIC OFFICE CENTRE Fulton Road HA9 (PENDING Jul18)	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>A critical trunk sewer runs through this site which would need to be considered</p>
-------	---	----------------	--	--

33963	BCSA6: WATKIN ROAD, Wembley	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	--------------------------------	----------------	--	-----

59876	BCSA7: WEMBLEY PARK STATION (NORTH and SOUTH)	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	---	----------------	--	-----

33959	BCSA8: WEMBLEY RETAIL PARK	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	----------------------------	----------------	--	-----

59877	BCSA9: FIRST WAY, Wembley, HA0	Affinity Water	<p>The scale of development/s is likely to require upgrades to the wastewater network. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing and infrastructure phasing plan. The plan should determine the magnitude of spare capacity currently available within the network and what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	N/A
-------	-----------------------------------	----------------	--	-----

59879	BEGA1 NEASDEN STATIONS GROWTH AREA, Neasden Lane, Denzil Road and Selbie Avenue NW10.	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	---	---	---	-----

59881	BEGA2 STAPLES CORNER GROWTH AREA, Staples Corner Strategic Industrial Land, adjacent to the Edgware	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	---	--	---	-----

59882	BESA1 COOMBE ROAD, Land at Coombe Road	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website  <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>On the information available to date we do not envisage concerns regarding wastewater treatment capacity in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>The critical Hendon Branch Trunk Sewer runs through this site which will need to be considered.</p>
-------	---	---	--	--

59884	BESA2 CRICKLEWOOD BUS DEPOT EDGWARE ROAD NW2 6JP	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	N/A
-------	--	--	---	-----

59887	BNSA1 CAPITOL WAY VALLEY, Edgware Road NW9 0AS	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
59888	BNSA2: COLINDALE RETAIL PARK, MULTI- STOREY CAR PARK AND SOUTHON HOUSE	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

59889	BNSA3: QUEENSBURY LSIS AND MORRISONS, Honeypot Lane, NW9	Affinity Water	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	N/A
59890	BNSA4: BURNT OAK GROWTH AREA – FORMER MECCA BINGO SITE	Affinity Water		We are unable to assess this site as no figures have been provided.
59891	BNWGA1 - NORTHWICK PARK GROWTH AREA (ALLOCATED SITE PENDING)	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

59893	BNWSA1: KENTON ROAD SAINSBURY'S AND ADJOINING LAND		On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	N/A
55474	BSESA1: AUSTEN, Cambridge Road	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	N/A

55441	BSESA10: NEVILLE AND WINTERLEY'S, Denmark Road	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	--	--	---	-----

55435	BSESA11: OLD GRANVILLE OPEN SPACE, Granville Road	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	<p>There is a large diameter critical storm relief sewer running through this site which would need to be considered.</p>
59917	BSESA12: WORDSWORTH, MASEFIELD AND PART OF SOUTH KILBURN OPEN SPACE	<p>Due to the complexities of water networks the level of information contained in this document does not allow Thames Water to make a detailed assessment of the impact the proposed housing provision will have on the water infrastructure and its cumulative impact. To enable us to provide more specific comments on the site proposals we require details of the Local Authority's aspiration for each site. For example, an indication of the location, type and scale of development together with the anticipated timing of development.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	

		We are unable to assess this site as no figures have been provided.		
55479	BSESA13: JOHN RATCLIFFE HOUSE, Chippenham Gardens, London, NW6 5LH	On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	There is a large diameter critical storm relief sewer running through this site which would need to be considered. A critical trunk sewer runs under the road adjacent to this site which would need to be considered.

55480	BSESA14: WILLIAM DUNBAR HOUSE AND WILLIAM SAVILLE HOUSE, Denmark Road, NW6 5DE.	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	---	---	---	-----

59918	BSESA15: UK ALBANIAN MUSLIM COMMUNITY AND CULTURAL CENTRE, Carlton Vale, NW6 5DA	<p>Due to the complexities of water networks the level of information contained in this document does not allow Thames Water to make a detailed assessment of the impact the proposed housing provision will have on the water infrastructure and its cumulative impact. To enable us to provide more specific comments on the site proposals we require details of the Local Authority's aspiration for each site. For example, an indication of the location, type and scale of development together with the anticipated timing of development.</p> <p>We are unable to assess this site as no figures have been provided</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
59920	BSESA16: OK Club, Neville Road and Christian Holt House.	<p>Due to the complexities of water networks the level of information contained in this document does not allow Thames Water to make a detailed assessment of the impact the proposed housing provision will have on the water infrastructure and its cumulative impact. To enable us to provide more specific comments on the site proposals we require details of the Local Authority's aspiration for each site. For example, an indication of the location, type and scale of development together with the anticipated timing of</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

development.

We are unable to assess this site as  
no figures have been provided

59921	BSESA17: CRICKLEWOOD BROADWAY RETAIL PARK, Cricklewood Broadway, London, NW2 6JN.	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	--	---	---	-----

59922	BSESA18: 245-289 CRICKLEWOOD BROADWAY, London, NW2 6NX	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	N/A
55452	BSESA2: BLAKE, Malvern Road	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way,</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

		Rickmansworth, Hertfordshire, WD3 9SQ		
55440	BSESA3: CARLTON HOUSE, Denmark Road	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

55451	BSESA4: CARLTON INFANT SCHOOL, Malvern Place	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
55454	BSESA5: CRAIK, Malvern Road	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way,</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A

Rickmansworth, Hertfordshire, WD3  
9SQ

55477	BSESA6: CRONE AND ZANGWILL, Rupert Road, Canterbury Road	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	--	--	---	-----

55476	BSESA7: DICKENS, Malvern Road	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	----------------------------------	---	---	-----

55434	BSESA8: HEREFORD HOUSE AND EXETER COURT, Carlton Vale	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website  <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	<p>There is a large diameter critical storm relief sewer running through this site which would need to be considered.</p>
59915	BSESA9: KILBURN PARK JUNIOR SCHOOL, Carlton Vale, NW6 5RG			open space

59895	BSSA1: ASIATIC CARPETS, High Road, NW10 2DA	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	N/A
-------	---	--	---	-----

59909	BSSA10: EURO CAR RENTAL, Brentfield Road, Stonebridge, London, NW10 8LD	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>Due to the complexities of water networks the level of information contained in this document does not allow Thames Water to make a detailed assessment of the impact the proposed housing provision will have on the water infrastructure and its cumulative impact. To enable us to provide more specific comments on the site proposals we require details of the Local Authority's aspiration for each site. For example, an indication of the location, type and scale of development together with the anticipated timing of development.</p>
-------	---	---	--

59896	BSSA2: B&M HOME STORE AND COBBOLD INDUSTRIAL ESTATE, Cobbold Road, NW10 9ST	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	n/a
-------	---	--	---	-----

59899	BSSA4: CHAPMAN'S AND SAPCOTE INDUSTRIAL ESTATE, High Road, NW10 2DH	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment.</p> <p>The developer can request information on network infrastructure by visiting the Thames Water website <a href="https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development">https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development</a>.</p>	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	n/a
-------	---	--	---	-----

59904	BSSA5: WILLESDEN BUS DEPOT, High Road, Willesden Green, NW10 2JY	<p>On the information available to date we do not envisage infrastructure concerns regarding water supply network infrastructure in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	n/a
17001	BSSA6: ARGENTA HOUSE AND WEMBLEY POINT	Affinity Water	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	n/a

59906	BSSA7: BRIDGE PARK AND UNISYS BUILDING, Brentfield, Stonebridge, London, NW10 0RG.	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	n/a
63665	BSWA10: ELM ROAD	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	n/a

59930	BSWSA2: SAINSBURY'S ALPERTON, Ealing Road HA0 1PF	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	n/a
59931	BSWSA3 ATLIP ROAD, Alperton, HA0	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	n/a

15528	BSWSA4 SUNLEIGH ROAD, Alperton, HA0	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	<p>A Thames Water Sewage Pumping Station is located within the proposed development boundary and this is contrary to best practice set out in Sewers for Adoption (7th edition). Future occupiers of the development should be made aware that they could periodically experience adverse amenity impacts from the pumping station in the form of odour; light; vibration and/or noise.</p>
21081	BSWSA5 ABBEY MANUFACTURING ESTATE, Mount Pleasant, Wembley, HA0 1NR	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	<p>A Thames Water Sewage Pumping Station is located within the proposed development boundary and this is contrary to best practice set out in Sewers for Adoption (7th edition). Future occupiers of the development should be made aware that they could periodically experience adverse amenity impacts from the pumping station in</p>

				the form of odour; light; vibration and/or noise.
59933	BSWSA6 BERESFORD AVENUE, Alperton, HA0	Affinity Water	<p>On the information available to date we do not envisage infrastructure concerns regarding wastewater networks in relation to this development/s. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to advise of the developments phasing. Please contact Thames Water Development Planning, either by email Devcon.team@thameswater.co.uk tel: 02035779998 or in writing Thames Water Utilities Ltd, Maple Lodge STW, Denham Way, Rickmansworth, Hertfordshire, WD3 9SQ</p>	n/a
21079	BSWSA8 WEMBLEY HIGH ROAD, Wembley, HA9	Affinity Water	<p>The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>	n/a

59936	BSWSA9: FORMER COPLAND SCHOOL, Wembley, HA9 (Pending)	Affinity Water	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	n/a
59934	Former Northfield Industrial Estate, Beresford Avenue, Wembley, HA0	Affinity Water	The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application	A critical trunk sewer runs through this site which would need to be considered